



**KKB**

**MICRO TESTING LABS PVT. LTD.**

*In Pursuit of Excellence*



TC - 6355

Accredited by NABL, ISO 9001:2015 & ISO 45001: 2018 certified Laboratory, Approved by MoEF&CC

**TEST REPORT**

ULR –TC63552600000418F

Discipline : Chemical

Product Group : Water & Residues In Water

Sub Group : Ground Water

Report Reference Number: KMTPL/25-26/1695/WTR/08171

Issue Date: 03.02.2026

<b>Issued To:</b> M/s.Pebble Creek High Montessori school 1-13-88/134, A & B, A.S. Rao Nagar Behind Railway Resevation Counter, Secunderabad, Telangana 500062	<b>Lr. Reference No. &amp; Date</b>	--
	<b>Sample Receipt Date</b>	28.01.2026
	<b>Analysis Starting Date</b>	29.01.2026
	<b>Analysis Completion Date</b>	03.02.2026
<b>Sample Details:</b> Bore Water	<b>Quantity Received</b>	2L x 1 No in Plastic Can
	<b>Sample condition on Receipt</b>	Good
	<b>Source / Location</b>	--
<b>Tests Requested:</b> As mentioned below		

**TEST RESULTS**

S. No.	Parameter	UOM	Test Method	Requirements as per IS 10500:2012		Result
				Acceptable Limit	Permissible Limit	
1	pH	--	IS 3025 : 2022 Part 11	6.5 -8.5	No relaxation	7.02
2	Color	CU	IS 3025 : 2018 Part 4	5 Max.	15 Max.	1
3	Odor	--	IS 3025 : 2021 Part 5	Agreeable	Agreeable	Agreeable
4	Electrical Conductivity	µS/cm	2510 B APHA 24 <sup>th</sup> Edition 2023	Not Specified	Not Specified	930
5	Turbidity	NTU	IS 3025 : 2023 Part 10	1.0 Max.	5.0 Max	BDL
6	Total Dissolved Solids @180 <sup>o</sup> C	mg/l	IS 3025 : 2023 Part 16	500 Max.	2000 Max.	589
7	Total Hardness as CaCO <sub>3</sub>	mg/l	IS 3025 : 2009 Part 21 RA 2023	200 Max.	600 Max.	349
8	Non Carbonate Hardness as CaCO <sub>3</sub>	mg/l	IS 3025 : 2009 Part 21 RA 2023	Not Specified	Not Specified	94
9	Calcium as Ca	mg/l	IS 3025:1991 Part 40 RA2019 Amd 1	75 Max.	200 Max.	71.5
10	Magnesium as Mg	mg/l	3500 Mg B APHA 24 <sup>th</sup> Edition 2023	30 Max.	100 Max.	41.5
11	Total Alkalinity as CaCO <sub>3</sub>	mg/l	IS 3025 : 2023 Part 23	200 Max.	600 Max.	255
12	Chlorides as Cl	mg/l	IS 3025 : 2025 Part 32	250 Max.	1000 Max.	75.4
13	Sodium as Na	mg/l	IS 3025 : 2024 Part 45	Not Specified	Not Specified	37
14	Potassium as K	mg/l	IS 3025 : 2024 Part 45	Not Specified	Not Specified	3.6
15	Sulphates as SO <sub>4</sub>	mg/l	4500 SO <sub>4</sub> <sup>-2</sup> E APHA 24 <sup>th</sup> Edition 2023	200 Max.	400 Max.	78
16	Nitrates as NO <sub>3</sub>	mg/l	4500 NO <sub>3</sub> <sup>-</sup> APHA 24 <sup>th</sup> Edition 2023	45 Max.	No relaxation	3.9
17	Silica as SiO <sub>2</sub>	mg/l	IS: 3025 : 1988 Part 35 RA 2019	Not Specified	Not Specified	1.9
18	Iron as Fe	mg/l	IS: 3025 : 2003 Part 53 RA 2019	0.3 Max.	No relaxation	BDL
19	Fluoride as F	mg/l	4500 F D APHA 24 <sup>th</sup> Edition 2023	1.0 Max.	1.5 Max.	0.62

UOM : Unit of Measurement; BDL : Below Detection Limit

Detection Limit : Turbidity : 0.1 NTU; Iron:0.1 mg/l.

Disclaimer: The results are applicable only to the sample tested. Endorsement of the product is neither inferred nor implied.

Verified by  
Venkata Phani C  
Sr. Manager

Authorized Signatory  
Amrutha Nalini  
Sr. Chemist

\* End of the Report \*

**KKB****MICRO TESTING LABS PVT. LTD.***In Pursuit of Excellence*

Accredited by NABL (TC-6355), ISO 9001:2015 &amp; ISO 45001: 2018 certified Laboratory, Approved by MoEF&amp;CC

**TEST REPORT**

Report Reference Number: KMTLPL/25-26/1695A/WTR/08171

Issue Date: 03.02.2026

<b>Issued To:</b> M/s.Pebble Creek High Montessori school 1-13-88/134, A & B, A.S. Rao Nagar Behind Railway Resevation Counter, Secunderabad, Telangana 500062	<b>Lr. Reference No. &amp; Date</b>	CRF dt. 28.01.2026
	<b>Sample Receipt Date</b>	28.01.2026
	<b>Analysis Starting Date</b>	29.01.2026
	<b>Analysis Completion Date</b>	03.02.2026
<b>Sample Details:</b> Bore Water	<b>Quantity Received</b>	1 L x 1 No. in pet bottle
	<b>Sample condition on Receipt</b>	Good
	<b>Source / Location</b>	--
<b>Tests Requested:</b> As mentioned below		

**TEST RESULTS**

S. No.	Parameter	UOM	Test Method	Requirement as per IS 10500 : 2012 (Acceptable Limit)	Result
1	Total Bacterial Count	per mL	IS 5402 : 2012	100 Max*	160
2	Total No. of Coliforms	per mL	IS 5401 : 2002 Part 1	Shall be Absent	Absent
3	Detection of E. Coli	per mL	IS 5887 : 1976 Part 1	Shall be Absent	Absent

UOM : Unit of Measurement

The requirement mentioned with "\*" is as per IS 14543 2021

Disclaimer: The results are applicable only to the sample tested. Endorsement of the product is neither inferred nor implied.

Verified by  
Venkata Phani C  
Sr. ManagerAuthorized Signatory  
Amrutha Nalini  
Sr. Chemist

\* End of the Report \*



KKB

# MICRO TESTING LABS PVT. LTD.

*In Pursuit of Excellence*

Accredited by NABL (TC-6355), ISO 9001:2015 & ISO 45001: 2018 certified Laboratory, Approved by MoEF&CC

## TEST REPORT

Report Reference Number: KMTLPL/25-26/1695A/WTR/08171

Issue Date: 03.02.2026

<b>Issued To:</b> M/s.Pebble Creek High Montessori school 1-13-88/134, A & B, A.S. Rao Nagar Behind Railway Resevation Counter, Secunderabad, Telangana 500062	<b>Lr. Reference No. &amp; Date</b>	CRF dt. 28.01.2026
	<b>Sample Receipt Date</b>	28.01.2026
	<b>Analysis Starting Date</b>	29.01.2026
	<b>Analysis Completion Date</b>	03.02.2026
<b>Sample Details:</b> Bore Water	<b>Quantity Received</b>	1 L x 1 No. in pet bottle
	<b>Sample condition on Receipt</b>	Good
	<b>Source / Location</b>	--
<b>Tests Requested:</b> As mentioned below		

## TEST RESULTS

S. No.	Parameter	UOM	Test Method	Requirement as per IS 10500 : 2012 (Acceptable Limit)	Result
1	Total Bacterial Count	per mL	IS 5402 : 2012	100 Max*	160
2	Total No. of Coliforms	per mL	IS 5401 : 2002 Part 1	Shall be Absent	Absent
3	Detection of E. Coli	per mL	IS 5887 : 1976 Part 1	Shall be Absent	Absent

UOM : Unit of Measurement

The requirement mentioned with "\*" is as per IS 14543 2021

Disclaimer: The results are applicable only to the sample tested. Endorsement of the product is neither inferred nor implied.

Verified by  
Venkata Phani C  
Sr. Manager

Authorized Signatory  
Amrutha Nalini  
Sr. Chemist

\* End of the Report\*



KKB

MICRO TESTING LABS PVT. LTD.

In Pursuit of Excellence



TC - 6355

Accredited by NABL, ISO 9001:2015 &amp; ISO 45001: 2018 certified Laboratory, Approved by MoEF&amp;CC

## TEST REPORT

ULR – TC63552600000419F

Discipline : Chemical

Product Group : Water &amp; Residues in Water

Sub Group : Drinking Water

Report Reference Number: KMTLPL/25-26/1695/WTR/08172

Issue Date: 03.02.2026

<b>Issued To:</b> M/s.Pebble Creek High Montessori school 1-13-88/134, A & B, A.S. Rao Nagar Behind Railway Resevation Counter, Secunderabad, Telangana 500062	<b>Lr. Reference No. &amp; Date</b>	--
	<b>Sample Receipt Date</b>	28.01.2026
	<b>Analysis Starting Date</b>	29.01.2026
	<b>Analysis Completion Date</b>	03.02.2026
<b>Sample Details:</b> Drinking Water	<b>Quantity Received</b>	2L x 1 No in Plastic Can
	<b>Sample condition on Receipt</b>	Good
	<b>Source / Location</b>	--

Tests Requested: As mentioned below

## TEST RESULTS

S. No.	Parameter	UOM	Test Method	Requirements as per IS 10500:2012		Result
				Acceptable Limit	Permissible Limit	
1	pH	--	IS 3025 : 2022 Part 11	6.5 -8.5	No relaxation	6.71
2	Color	CU	IS 3025 : 2018 Part 4	5 Max.	15 Max.	1
3	Odor	--	IS 3025 : 2021 Part 5	Agreeable	Agreeable	Agreeable
4	Electrical Conductivity	µS/cm	2510 B APHA 24 <sup>th</sup> Edn 2023	Not Specified	Not Specified	150
5	Turbidity	NTU	IS 3025 : 2023 Part 10	1.0 Max.	5.0 Max.	BDL
6	Total Dissolved Solids @180 <sup>o</sup> C	mg/l	IS 3025 : 2023 Part 16	500 Max.	2000 Max.	87
7	Total Hardness as CaCO <sub>3</sub>	mg/l	IS 3025 : 2009 Part 21 RA 2023	200 Max.	600 Max.	29.1
8	Non Carbonate Hardness as CaCO <sub>3</sub>	mg/l	IS 3025 : 2009 Part 21 RA 2023	Not Specified	Not Specified	BDL
9	Calcium as Ca	mg/l	IS 3025:1991 Part 40RA2019 Amd1	75 Max.	200 Max.	7.0
10	Magnesium as Mg	mg/l	3500 Mg B APHA 24 <sup>th</sup> Edn 2023	30 Max.	100 Max.	2.8
11	Total Alkalinity as CaCO <sub>3</sub>	mg/l	IS 3025 : 2023 Part 23	200 Max.	600 Max.	34.1
12	Chlorides as Cl	mg/l	IS 3025 : 2025 Part 32	250 Max.	1000 Max.	18.9
13	Sodium as Na	mg/l	IS 3025 : 2024 Part 45	Not Specified	Not Specified	11
14	Potassium as K	mg/l	IS 3025 : 2024 Part 45	Not Specified	Not Specified	BDL
15	Sulphates as SO <sub>4</sub>	mg/l	4500 SO <sub>4</sub> <sup>-2</sup> E APHA 24 <sup>th</sup> Edn 2023	200 Max.	400 Max.	3.3
16	Nitrates as NO <sub>3</sub>	mg/l	4500 NO <sub>3</sub> <sup>-</sup> APHA 24 <sup>th</sup> Edn 2023	45 Max.	No relaxation	BDL
17	Silica as SiO <sub>2</sub>	mg/l	IS: 3025 : 1988 Part 35 RA 2019	Not Specified	Not Specified	BDL
18	Iron as Fe	mg/l	IS: 3025 : 2003 Part 53 RA 2019	0.3 Max.	No relaxation	BDL
19	Fluoride as F	mg/l	4500 F <sup>-</sup> D APHA 24 <sup>th</sup> Edn 2023	1.0 Max.	1.5 Max.	0.08

UOM : Unit of Measurement; BDL : Below Detection Limit

Detection Limit : Turbidity : 0.1 NTU; Potassium : 1.0 mg/l; Nitrates : 0.1 mg/l; Silica : 0.1 mg/l; Iron: 0.1 mg/l.

Disclaimer: The results are applicable only to the sample tested. Endorsement of the product is neither inferred nor implied.

Verified by  
Venkata Phani C  
Sr. ManagerAuthorized Signatory  
Amrutha Nalini  
Sr. Chemist

\* End of the Report \*



KKB

MICRO TESTING LABS PVT. LTD.

In Pursuit of Excellence

Accredited by NABL (TC-6355), ISO 9001:2015 & ISO 45001: 2018 certified Laboratory, Approved by MoEF&CC

**TEST REPORT**

Report Reference Number: KMTLPL/25-26/1695A/WTR/08172

Issue Date: 03.02.2026

<b>Issued To:</b> M/s.Pebble Creek High Montessori school 1-13-88/134, A & B, A.S. Rao Nagar Behind Railway Resevation Counter, Secunderabad, Telangana 500062	Lr. Reference No. & Date	CRF dt. 28.01.2026
	Sample Receipt Date	28.01.2026
	Analysis Starting Date	29.01.2026
	Analysis Completion Date	03.02.2026
<b>Sample Details:</b> Drinking Water	Quantity Received	1 L x 1 No. In pet bottle
	Sample condition on Receipt	Good
	Source / Location	--
<b>Tests Requested:</b> As mentioned below		

**TEST RESULTS**

S. No.	Parameter	UOM	Test Method	Requirement as per IS 10500 : 2012 (Acceptable Limit)	Result
1	Total Bacterial Count	per mL	IS 5402 : 2012	100 Max*	40
2	Total No. of Coliforms	per mL	IS 5401 : 2002 Part 1	Shall be Absent	Absent
3	Detection of E. Coli	per mL	IS 5887 : 1976 Part 1	Shall be Absent	Absent

UOM : Unit of Measurement

The requirement mentioned with "\*" is as per IS 14543 2021.

Disclaimer: The results are applicable only to the sample tested. Endorsement of the product is neither inferred nor implied.

Verified by  
Venkata Phani C  
Sr. Manager

Authorized Signatory  
Amrutha Nalini  
Sr. Chemist

\* End of the Report\*



KKB

MICRO TESTING LABS PVT. LTD.

In Pursuit of Excellence



TC - 6355

Accredited by NABL, ISO 9001:2015 &amp; ISO 45001: 2018 certified Laboratory, Approved by MoEF&amp;CC

## TEST REPORT

ULR – TC63552600000416F

Discipline : Chemical

Product Group : Water &amp; Residues in Water

Sub Group : Ground Water

Report Reference Number: KMTLPL/25-26/1694/WTR/08169

Issue Date: 03.02.2026

Issued To: M/s.Pebble Creek Life School 4-43/1,Opposite Moghulla Ramakrishna Function Hall, Thumkunta,Shameerpet (M),Hyderabad - 500078	Lr. Reference No. & Date	--
	Sample Receipt Date	28.01.2026
Sample Details: Bore Water	Analysis Starting Date	29.01.2026
	Analysis Completion Date	03.02.2026
	Quantity Received	2L x 1 No in Plastic Can
	Sample condition on Receipt	Good
	Source / Location	--

Tests Requested: As mentioned below

## TEST RESULTS

S. No.	Parameter	UOM	Test Method	Requirements as per IS 10500:2012		Result
				Acceptable Limit	Permissible Limit	
1	pH	--	IS 3025 : 2022 Part 11	6.5 - 8.5	No relaxation	7.31
2	Color	CU	IS 3025 : 2018 Part 4	5 Max.	15 Max.	1
3	Odor	--	IS 3025 : 2021 Part 5	Agreeable	Agreeable	Agreeable
4	Electrical Conductivity	µS/cm	2510 B APHA 24 <sup>th</sup> Edition 2023	Not Specified	Not Specified	1290
5	Turbidity	NTU	IS 3025 : 2023 Part 10	1.0 Max.	5.0 Max	BDL
6	Total Dissolved Solids @180 <sup>o</sup> C	mg/l	IS 3025 : 2023 Part 16	500 Max.	2000 Max.	819
7	Total Hardness as CaCO <sub>3</sub>	mg/l	IS 3025 : 2009 Part 21 RA 2023	200 Max.	600 Max.	512
8	Non Carbonate Hardness as CaCO <sub>3</sub>	mg/l	IS 3025 : 2009 Part 21 RA 2023	Not Specified	Not Specified	76
9	Calcium as Ca	mg/l	IS 3025:991 Part 40 RA2019 Amd 1	75 Max.	200 Max.	106
10	Magnesium as Mg	mg/l	3500 Mg B APHA 24 <sup>th</sup> Edition 2023	30 Max.	100 Max.	60.4
11	Total Alkalinity as CaCO <sub>3</sub>	mg/l	IS 3025 : 2023 Part 23	200 Max.	600 Max.	436
12	Chlorides as Cl	mg/l	IS 3025 : 2025 Part 32	250 Max.	1000 Max.	71.7
13	Sodium as Na	mg/l	IS 3025 : 2024 Part 45	Not Specified	Not Specified	45
14	Potassium as K	mg/l	IS 3025 : 2024 Part 45	Not Specified	Not Specified	4.1
15	Sulphates as SO <sub>4</sub>	mg/l	4500 SO <sub>4</sub> <sup>-2</sup> E APHA 24 <sup>th</sup> Edition 2023	200 Max.	400 Max.	79
16	Nitrates as NO <sub>3</sub>	mg/l	4500 NO <sub>3</sub> <sup>-</sup> APHA 24 <sup>th</sup> Edition 2023	45 Max.	No relaxation	4.9
17	Silica as SiO <sub>2</sub>	mg/l	IS: 3025 : 1988 Part 35 RA 2019	Not Specified	Not Specified	2.4
18	Iron as Fe	mg/l	IS: 3025 : 2003 Part 53 RA 2019	0.3 Max.	No relaxation	BDL
19	Fluoride as F	mg/l	4500 F <sup>-</sup> D APHA 24 <sup>th</sup> Edition 2023	1.0 Max.	1.5 Max.	0.78

UOM : Unit of Measurement; BDL : Below Detection Limit

Detection Limit : Turbidity : 0.1 NTU; Iron:0.1 mg/l.

Disclaimer: The results are applicable only to the sample tested. Endorsement of the product is neither inferred nor implied.

Verified by  
Venkata Phani C  
Sr. Manager

Authorized Signatory  
Amrutha Nalini  
Sr. Chemist

\* End of the Report \*

**KKB****MICRO TESTING LABS PVT. LTD.***In Pursuit of Excellence*

Accredited by NABL (TC-6355), ISO 9001:2015 &amp; ISO 45001: 2018 certified Laboratory, Approved by MoEF&amp;CC

**TEST REPORT**

Report Reference Number: KMTLPL/25-26/1694A/WTR/08169

Issue Date: 03.02.2026

<b>Issued to:</b> M/s.Pebble Creek Life School 4-43/1,Opposite Moghulla Ramakrishna Function Hall, Thumkunta,Shameerpet (M),Hyderabad - 500078	<b>Lr. Reference No. &amp; Date</b>	CRF dt. 28.01.2026
	<b>Sample Receipt Date</b>	28.01.2026
	<b>Analysis Starting Date</b>	29.01.2026
	<b>Analysis Completion Date</b>	03.02.2026
<b>Sample Details:</b> Bore Water	<b>Quantity Received</b>	1 L x 1 No. in pet bottle
	<b>Sample condition on Receipt</b>	Good
	<b>Source / Location</b>	Borewell
<b>Tests Requested:</b> As mentioned below		

**TEST RESULTS**

S. No.	Parameter	UOM	Test Method	Requirement as per IS 10500 : 2012 (Acceptable Limit)	Result
1	Total Bacterial Count	per mL	IS 5402 : 2012	100 max*	190
2	Total No. of Coliforms	per mL	IS 5401 : 2002 Part 1	Shall be Absent	Absent
3	Detection of E. Coli	per mL	IS 5887 : 1976 Part 1	Shall be Absent	Absent

UOM : Unit of Measurement

The requirement mentioned with "\*" is as per IS 14543 : 2021

Disclaimer: The results are applicable only to the sample tested. Endorsement of the product is neither inferred nor implied.

Verified by  
Venkata Phani C  
Sr. ManagerAuthorized Signatory  
Amrutha Nalini  
Sr. Chemist

\* End of the Report \*



KKB

MICRO TESTING LABS PVT. LTD.

In Pursuit of Excellence



TC - 6355

Accredited by NABL, ISO 9001:2015 &amp; ISO 45001: 2018 certified Laboratory, Approved by MoEF&amp;CC

## TEST REPORT

ULR – TC63552600000417F

Discipline : Chemical

Product Group : Water &amp; Residues In Water

Sub Group : Drinking Water

Report Reference Number: KMTLPL/25-26/1694/WTR/08170

Issue Date: 03.02.2026

<b>Issued To:</b> M/s.Pebble Creek Life School 4-43/1,Opposite Moghulla Ramakrishna Function Hall, Thumkunta,Shameerpet (M),Hyderabad - 500078	<b>Lr. Reference No. &amp; Date</b>	--
<b>Sample Details:</b> Drinking Water	<b>Sample Receipt Date</b>	28.01.2026
	<b>Analysis Starting Date</b>	29.01.2026
	<b>Analysis Completion Date</b>	03.02.2026
	<b>Quantity Received</b>	2L x 1 No in Plastic Can
	<b>Sample condition on Receipt</b>	Good
	<b>Source / Location</b>	--
<b>Tests Requested:</b> As mentioned below		

## TEST RESULTS

S. No.	Parameter	UOM	Test Method	Requirements as per IS 10500:2012		Result
				Acceptable Limit	Permissible Limit	
1	pH	--	IS 3025 : 2022 Part 11	6.5 -8.5	No relaxation	6.59
2	Color	CU	IS 3025 : 2018 Part 4	5 Max.	15 Max.	1
3	Odor	--	IS 3025 : 2021 Part 5	Agreeable	Agreeable	Agreeable
4	Electrical Conductivity	µS/cm	2510 B APHA 24 <sup>th</sup> Edition 2023	Not Specified	Not Specified	80
5	Turbidity	NTU	IS 3025 : 2023 Part 10	1.0 Max.	5.0 Max.	BDL
6	Total Dissolved Solids @180 <sup>o</sup> C	mg/l	IS 3025 : 2023 Part 16	500 Max.	2000 Max.	36
7	Total Hardness as CaCO <sub>3</sub>	mg/l	IS 3025 : 2009 Part 21 RA 2023	200 Max.	600 Max.	13.6
8	Non Carbonate Hardness as CaCO <sub>3</sub>	mg/l	IS 3025 : 2009 Part 21 RA 2023	Not Specified	Not Specified	BDL
9	Calcium as Ca	mg/l	IS 3025:1991 Part 40 RA2019 Amd 1	75 Max.	200 Max.	3.1
10	Magnesium as Mg	mg/l	3500 Mg B APHA 24 <sup>th</sup> Edition 2023	30 Max.	100 Max.	1.4
11	Total Alkalinity as CaCO <sub>3</sub>	mg/l	IS 3025 : 2023 Part 23	200 Max.	600 Max.	19.8
12	Chlorides as Cl	mg/l	IS 3025 : 2025 Part 32	250 Max.	1000 Max.	11.3
13	Sodium as Na	mg/l	IS 3025 : 2024 Part 45	Not Specified	Not Specified	9.0
14	Potassium as K	mg/l	IS 3025 : 2024 Part 45	Not Specified	Not Specified	BDL
15	Sulphates as SO <sub>4</sub>	mg/l	4500 SO <sub>4</sub> <sup>-2</sup> E APHA 24 <sup>th</sup> Edition 2023	200 Max.	400 Max.	BDL
16	Nitrates as NO <sub>3</sub>	mg/l	4500 NO <sub>3</sub> <sup>-</sup> APHA 24 <sup>th</sup> Edition 2023	45 Max.	No relaxation	BDL
17	Silica as SiO <sub>2</sub>	mg/l	IS: 3025 : 1988 Part 35 RA 2019	Not Specified	Not Specified	BDL
18	Iron as Fe	mg/l	IS: 3025 : 2003 Part 53 RA 2019	0.3 Max.	No relaxation	BDL
19	Fluoride as F	mg/l	4500 F <sup>-</sup> D APHA 24 <sup>th</sup> Edition 2023	1.0 Max.	1.5 Max.	BDL

UOM : Unit of Measurement; BDL : Below Detection Limit

Detection Limit : Turbidity : 0.1 NTU; Potassium : 1.0 mg/l; Sulphates : 1.0 mg/l; Nitrates : 0.1 mg/l; Silica : 0.1 mg/l; Iron:0.1 mg/l; Fluoride : 0.01 mg/l.

Disclaimer: The results are applicable only to the sample tested. Endorsement of the product is neither inferred nor implied.

Verified by  
Venkata Phani C  
Sr. ManagerAuthorized Signatory  
Amrutha Nalini  
Sr. Chemist

\* End of the Report \*

**KKB****MICRO TESTING LABS PVT. LTD.***In Pursuit of Excellence*

Accredited by NABL (TC-6355), ISO 9001:2015 &amp; ISO 45001: 2018 certified Laboratory, Approved by MoEF&amp;CC

**TEST REPORT**

Report Reference Number: KMTLPL/25-26/1694A/WTR/08170

Issue Date: 03.02.2026

<b>Issued to:</b> M/s.Pebble Creek Life School 4-43/1,Opposite Moghulla Ramakrishna Function Hall, Thumkunta,Shameerpet (M),Hyderabad - 500078	<b>Lr. Reference No. &amp; Date</b>	CRF dt. 28.01.2026
	<b>Sample Receipt Date</b>	28.01.2026
	<b>Analysis Starting Date</b>	29.01.2026
	<b>Analysis Completion Date</b>	03.02.2026
<b>Sample Details:</b> Drinking Water	<b>Quantity Received</b>	1 L x 1 No. in pet bottle
	<b>Sample condition on Receipt</b>	Good
	<b>Source / Location</b>	--
<b>Tests Requested:</b> As mentioned below		

**TEST RESULTS**

S. No.	Parameter	UOM	Test Method	Requirement as per IS 10500 : 2012 (Acceptable Limit)	Result
1	Total Bacterial Count	per mL	IS 5402 : 2012	100 Max*	60
2	Total No. of Coliforms	per mL	IS 5401 : 2002 Part 1	Shall be Absent	Absent
3	Detection of E. Coli	per mL	IS 5887 : 1976 Part 1	Shall be Absent	Absent

UOM : Unit of Measurement

The requirement mentioned with "\*" is as per IS 14543 2021

Disclaimer: The results are applicable only to the sample tested. Endorsement of the product is neither inferred nor implied.

Verified by  
Venkata Phani C  
Sr. ManagerAuthorized Signatory  
Amrutha Nalini  
Sr. Chemist

\* End of the Report\*